EMERGENCY RESPONSE PLAN P

Page (1 of 4)

Doc#: SWP-P11

Date: December 20, 2016

PURPOSE:

To provide guidance for management of emergency discharges of sewer.

APPLICABLE REGULATIONS:

None known.

PROCEDURE:

- 1. The Sacheen Lake Sewer and Water District will follow the recommendations of the Wastewater Collection System Emergency Response Plan as prepared by James A. Sewell & Associates.
- 2. The District Manager shall notify Northeast Tri-county Health and WDOE of any substantial leaks or any leaks that impact surface waters within 24 hours of any identified leak.